



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.72				
2	7.69	55			
3	7.66				
4	7.65				
5	7.64				
6	7.64				
7	7.58				
8	7.64	50			
9	7.69				
10	7.65				
11	7.66				
12	7.62				
13	7.68				
14	7.65				
15	7.69				
16	7.57	44			
17	7.62				
18	7.58				
19	7.60				
20	7.58				
21	7.62				
22	7.69				
23	7.66	40			
24	7.64				
25	7.59				
26	7.55				
27	7.58	40			
28	7.59				
29	7.52				
30	7.49				
31	7.56				

<<Have minimums been met for this day?

County: Tillamook Agency: C

ENTRY POINT

A

PWS ID 4100367

HEBO JOINT WATER & SANITARY AUTH.

Sample period: August / 2024
Month/Year

Number of excursions* during this month: 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2



Print Name: Justin H. Ford
Signature: [Signature]
Date: 09/08/2024

(No = N = Excursion) Total N's 1

Send to OHD within 10 days after end of sampling period

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381