

Day	pH	Alk	Phos	Other	Y/N
1	7.50	60			Y
2	7.52				
3	7.56	61			
4	7.54				
5	7.60	60			
6	7.63				
7	7.56				
8	7.59				
9	7.58				
10	7.55				
11	7.58	60			
12	7.60				
13	7.55				
14	7.50				
15	7.52				
16	7.52	60			
17	7.56				
18	7.55				
19	7.46				
20	7.40				
21	7.39				
22	7.42	60			
23	7.50	61			
24	7.52	63			
25	7.55	65			
26	7.60	64			
27	7.63	66			
28	7.66	62			
29	7.64	67			
30	7.66	66			Y
31					

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100367**

**HEBO JOINT WATER & SANITARY AUTH**

Sample period: November, 2024  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2  
 Alk 60.0 (Alkalinity)

Print Name: Justin Hartford

Signature: [Signature]

Date & Phone#: 12/05/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's