

Day	pH	Alk	Phos	Other	Y/N
1	7.41	64			Y
2	7.40				
3	7.32				
4	7.43				
5	7.45				
6	7.41				
7	7.44				
8	7.40				
9	7.51	70			
10	7.50				
11	7.38				
12	7.42				
13	7.44				
14	7.50				
15	7.44				
16	7.39				
17	7.41				
18	7.44				
19	7.45	67			
20	7.47				
21	7.44				
22	7.45				
23	7.46				
24	7.50				
25	7.57				
26	7.56				
27	7.54				
28	7.50	69			
29	7.45				
30	7.41				
31	7.37				Y

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100367**

**HEBO JOINT WATER & SANITARY AUTH**

Sample period: October 2025  
Month/Year

Number of excursions during this month: 11

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2  
Alk 60.0 (Alkalinity)

Print Name: Justin Harford  
Signature: [Signature]  
Date & Phone#: 11/10/25, 503 392 6100

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 11