

Day	pH	Alk	Phos	Other	Y/N
1	7.38	68			Y
2	7.37				Y
3	7.35				Y
4	7.36				Y
5	7.38				Y
6	7.35				Y
7	7.36				Y
8	7.37				Y
9	7.35				Y
10	7.34	69			Y
11	7.33				Y
12	7.30				Y
13	7.31				Y
14	7.30				Y
15	7.32				Y
16	7.28				Y
17	7.23				Y
18	7.24				Y
19	7.28				Y
20	7.30	67			Y
21	7.29				Y
22	7.25				Y
23	7.24				Y
24	7.20				Y
25	7.21				Y
26	7.20				Y
27	7.22				Y
28	7.24				Y
29	7.25				Y
30	7.24				Y
31	7.22	65			Y

<<Have minimums been met for this day?

County: Tillamook Agency: TILLAMOOK COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100367**

**HEBO JOINT WATER & SANITARY AUTH**

Sample period: December 2025  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 

7.2
-----

  
 Alk 

60.0
------

 (Alkalinity)

Print Name: Justin Hartford

Signature: [Signature]

Date & Phone#: 1/10/2026 503 3926600

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0