



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.62				Y
2	7.70				
3	7.66				
4	7.76				
5	7.57				
6	7.45				
7	7.54				
8	7.57				
9	7.53				
10	7.52				
11	7.66				
12	7.63				
13	7.59				
14	7.63				
15	7.58				
16	7.51				
17	7.62				
18	7.57				
19	7.62				
20	7.85				
21	7.77				
22	7.60				
23	7.66				
24	7.86				
25	7.78				
26	7.83				
27	7.70				
28	7.77				
29	7.79				
30	7.85				
31	8.05				Y

<<Have minimums been met for this day?

County Title: _____ Agency: _____

ENTRY POINT

A

PWS ID 4100367

HEBO JOINT WATER & SANITARY AUTH.

Sample period: JAN / 2021
 Month/Year

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: LONNY E. MOELLER

Signature: [Signature]

Date: FEB. 3, 2021

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period