



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

| Day | pH   | Alk | Phos | Sili | Y/N |
|-----|------|-----|------|------|-----|
| 1   | 7.61 |     |      |      | Y   |
| 2   | 7.62 |     |      |      | Y   |
| 3   | 7.61 |     |      |      | Y   |
| 4   | 7.62 |     |      |      | Y   |
| 5   | 7.52 |     |      |      | Y   |
| 6   | 7.73 |     |      |      | Y   |
| 7   | 7.60 |     |      |      | Y   |
| 8   | 7.62 |     |      |      | Y   |
| 9   | 7.59 |     |      |      | Y   |
| 10  | 7.59 |     |      |      | Y   |
| 11  | 7.62 |     |      |      | Y   |
| 12  | 7.50 |     |      |      | Y   |
| 13  | 7.59 |     |      |      | Y   |
| 14  | 7.57 |     |      |      | Y   |
| 15  | 7.53 |     |      |      | Y   |
| 16  | 7.44 |     |      |      | Y   |
| 17  | 7.61 |     |      |      | Y   |
| 18  | 7.51 |     |      |      | Y   |
| 19  | 7.60 |     |      |      | Y   |
| 20  | 7.51 |     |      |      | Y   |
| 21  | 7.51 |     |      |      | Y   |
| 22  | 7.54 |     |      |      | Y   |
| 23  | 7.59 |     |      |      | Y   |
| 24  | 7.50 |     |      |      | Y   |
| 25  | 7.48 |     |      |      | Y   |
| 26  | 7.46 |     |      |      | Y   |
| 27  | 7.47 |     |      |      | Y   |
| 28  | 7.47 |     |      |      | Y   |
| 29  | 7.41 |     |      |      | Y   |
| 30  | 7.46 |     |      |      | Y   |
| 31  |      |     |      |      | Y   |

<<Have minimums been met for this day?

County Tillamook Agency: C

**ENTRY POINT**

**A**

**PWS ID 4100367**

**HEBO JOINT WATER & SANITARY AUTH.**

Sample period: JUNE / 2021  
 Month/Year

Number of excursions\* during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: Lonny Moeller

Signature: [Signature]

Date: 7/8/21

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381