



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.46				Y
2	7.46				Y
3	7.45				Y
4	7.43				Y
5	7.39				Y
6	7.40				Y
7	7.30				Y
8	7.40				Y
9	7.43				Y
10	7.42				Y
11	7.39				Y
12	7.39				Y
13	7.44				Y
14	7.48				Y
15	7.48				Y
16	7.39				Y
17	7.44				Y
18	7.36				Y
19	7.40				Y
20	7.34				Y
21	7.35				Y
22	7.32				Y
23	7.41				Y
24	7.36				Y
25	7.34				Y
26	7.34				Y
27	7.27				Y
28	7.36				Y
29	7.57				Y
30	7.48				Y
31	7.44				Y

<<Have minimums been met for this day?

County Tillamook Agency: C

**ENTRY POINT**

**A**

**PWS ID 4100367**

**HEBO JOINT WATER & SANITARY AUTH.**

Sample period: Aug. 2021  
Month/Year

Number of excursions\* during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Print Name: LORRY E. MOELLER  
Signature: Lorry E. Moeller  
Date: 9/6/21

(No = N = Excursion) Total N's 0

Send to OHD within 10 days after end of sampling period

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381