



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

County: Tillamook Agency: C

ENTRY POINT

A

PWS ID 4100367

HEBO JOINT WATER & SANITARY AUTH.

Sample period: October/2021
Month/Year

Number of excursions* during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Reference

Minimum Water Quality Parameters as set by State:

pH 7.2

Day	pH	Alk	Phos	Sili	Y/N
1	7.34				Y
2	7.38				Y
3	7.37				Y
4	7.41				Y
5	7.49				Y
6	7.39				Y
7	7.51				Y
8	7.63				Y
9	7.63				Y
10	7.76				Y
11	7.75				Y
12	7.72				Y
13	7.77				Y
14	7.69				Y
15	7.70				Y
16	7.67				Y
17	7.63				Y
18	7.64				Y
19	7.77				Y
20	7.74				Y
21	7.78				Y
22	7.72				Y
23	7.78				Y
24	7.75				Y
25	7.81				Y
26	7.82				Y
27	7.91				Y
28	7.83				Y
29	7.86				Y
30	7.67				Y
31	7.57				Y

(No = N = Excursion) Total N's 0

Print Name: Talon C. Hiibschman

Signature: Talon C. Hiibschman

Date: 11/8/2021

Send to OHD within 10 days after end of sampling period

Oregon Health Division, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381