

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Jan	7.8	28	Y
2-Jan	7.9	32	Y
3-Jan	7.7	28	Y
4-Jan	7.8	28	Y
5-Jan	7.7	24	Y
6-Jan	7.8	26	Y
7-Jan	7.8	26	Y
8-Jan	7.8	30	Y
9-Jan	7.7	30	Y
10-Jan	7.7	28	Y
11-Jan	7.7	28	Y
12-Jan	7.8	28	Y
13-Jan	7.7	26	Y
14-Jan	7.7	22	Y
15-Jan	7.8	24	Y
16-Jan	7.8	26	Y
17-Jan	7.6	24	Y
18-Jan	7.8	26	Y
19-Jan	7.7	30	Y
20-Jan	7.8	28	Y
21-Jan	7.8	28	Y
22-Jan	7.7	28	Y
23-Jan	7.6	30	Y
24-Jan	7.7	32	Y
25-Jan	7.8	32	Y
26-Jan	7.6	34	Y
27-Jan	7.7	36	Y
28-Jan	7.8	36	Y
29-Jan	7.9	36	Y
30-Jan	7.8	36	Y
31-Jan	7.8	34	Y
(No = N = Excursion)	Total N's:	0	

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: Jan-21
Month / Year

Number of excursions this month:
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**


pH

Alk (alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Zac Bertz

Signature: 

Date: 1-Feb-21

Send to DWP within 10 days after end of sampling period.