

Oregon
Health
Authority

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Feb	7.7	32	Y
2-Feb	7.7	28	Y
3-Feb	7.7	26	Y
4-Feb	7.7	26	Y
5-Feb	7.8	26	Y
6-Feb	7.8	26	Y
7-Feb	7.7	28	Y
8-Feb	7.7	30	Y
9-Feb	7.7	30	Y
10-Feb	7.6	32	Y
11-Feb	7.8	32	Y
12-Feb	7.8	32	Y
13-Feb	7.8	32	Y
14-Feb	8.0	32	Y
15-Feb	7.8	30	Y
16-Feb	7.8	28	Y
17-Feb	7.7	28	Y
18-Feb	7.7	28	Y
19-Feb	7.7	28	Y
20-Feb	7.7	28	Y
21-Feb	7.8	28	Y
22-Feb	7.8	30	Y
23-Feb	7.6	26	Y
24-Feb	7.7	26	Y
25-Feb	7.8	28	Y
26-Feb	7.8	26	Y
27-Feb	7.7	26	Y
28-Feb	7.7	26	Y
(No = N = Excursion)	Total N's:	0	

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: Feb-21
Month / Year

Number of excursions this month:
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH

Alk (alkalinity)

PO4 (Orthophosphate)

Other

Print Name: Zac Bertz

Signature:
Date: 1-Mar-21

Send to DWP within 10 days after end of sampling period.