

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Sep	7.7	26	Y
2-Sep	7.7	26	Y
3-Sep	7.7	26	Y
4-Sep	7.6	26	Y
5-Sep	7.7	26	Y
6-Sep	7.6	26	Y
7-Sep	7.6	30	Y
8-Sep	7.7	28	Y
9-Sep	7.7	28	Y
10-Sep	7.7	28	Y
11-Sep	7.8	28	Y
12-Sep	7.7	30	Y
13-Sep	7.7	30	Y
14-Sep	7.6	30	Y
15-Sep	7.7	30	Y
16-Sep	7.5	30	Y
17-Sep	7.6	28	Y
18-Sep	7.6	26	Y
19-Sep	7.6	30	Y
20-Sep	7.7	30	Y
21-Sep	7.7	30	Y
22-Sep	7.6	30	Y
23-Sep	7.7	30	Y
24-Sep	7.5	32	Y
25-Sep	7.8	32	Y
26-Sep	7.8	32	Y
27-Sep	7.6	30	Y
28-Sep	7.8	32	Y
29-Sep	7.4	32	Y
30-Sep	7.6	32	Y
(No = N = Excursion)	Total N's:	0	

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: Sep-21
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input style="width: 80%;" type="text"/>	
Alk	<input style="width: 80%;" type="text"/>	(alkalinity)
PO4	<input style="width: 80%;" type="text"/>	(Orthophosphate)
Other	<input style="width: 80%;" type="text"/>	(_____)

Print Name: Zac Bertz

Signature: _____

Date: 4-Oct-21

Send to DWP within 10 days after end of sampling period.