

Oregon
Health
Authority

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Oct	7.8	32	Y
2-Oct	7.8	32	Y
3-Oct	7.7	32	Y
4-Oct	7.6	30	Y
5-Oct	7.7	32	Y
6-Oct	7.7	30	Y
7-Oct	7.7	32	Y
8-Oct	7.8	32	Y
9-Oct	7.8	32	Y
10-Oct	7.7	34	Y
11-Oct	7.6	28	Y
12-Oct	7.8	32	Y
13-Oct	7.7	34	Y
14-Oct	7.7	32	Y
15-Oct	7.7	32	Y
16-Oct	7.5	32	Y
17-Oct	7.5	34	Y
18-Oct	7.6	34	Y
19-Oct	7.7	34	Y
20-Oct	7.6	34	Y
21-Oct	7.6	34	Y
22-Oct	7.6	36	Y
23-Oct	7.7	34	Y
24-Oct	7.7	34	Y
25-Oct	7.7	32	Y
26-Oct	7.8	34	Y
27-Oct	7.7	32	Y
28-Oct	7.7	32	Y
29-Oct	7.7	34	Y
30-Oct	7.7	36	Y
31-Oct	7.6	28	Y
(No = N = Excursion)	Total N's:	0	

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: Oct-21
Month / Year

Number of excursions this month:
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality Parameters as set by

pH	<input style="width: 80%;" type="text"/>	
Alk	<input style="width: 80%;" type="text"/>	(alkalinity)
PO4	<input style="width: 80%;" type="text"/>	(Orthophosphate)
Other	<input style="width: 80%;" type="text"/>	(_____)

Print Name: Zac Bertz

Signature: Zachary T Bertz
Digitally signed by Zachary T Bertz
DN: cn=US, e=zac.bertz@hillsboro-oregon.gov, o=City of Hillsboro, ou=Water-WTP, cn=Zachary T Bertz
Reason: I attest to the accuracy and integrity of this document
Contact Info: 5037584446
Date: 2021.11.02 14:12:18-0700

Date: 2-Nov-21

Send to DWP within 10 days after end of sampling period.