

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Apr	7.8	36	Y
2-Apr	7.7	36	Y
3-Apr	7.6	36	Y
4-Apr	7.7	38	Y
5-Apr	7.8	32	Y
6-Apr	7.7	30	Y
7-Apr	7.7	30	Y
8-Apr	7.7	32	Y
9-Apr	7.8	30	Y
10-Apr	7.7	32	Y
11-Apr	7.8	32	Y
12-Apr	7.8	32	Y
13-Apr	7.6	34	Y
14-Apr	7.7	30	Y
15-Apr	7.8	32	Y
16-Apr	7.8	30	Y
17-Apr	7.7	30	Y
18-Apr	7.8	32	Y
19-Apr	7.7	36	Y
20-Apr	7.7	34	Y
21-Apr	7.8	30	Y
22-Apr	7.6	30	Y
23-Apr	7.6	30	Y
24-Apr	7.7	30	Y
25-Apr	7.6	30	Y
26-Apr	7.6	32	Y
27-Apr	7.7	34	Y
28-Apr	7.7	32	Y
29-Apr	7.6	32	Y
30-Apr	7.7	32	Y
(No = N = Excursion) Total N's:			0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission
Entry Point: Finished Water Pump Stations
Sample Period: Apr-22
 Month / Year

Number of excursions this month: 0

(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH
 Alk (alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Zac Bertz

Signature: _____

Date: 4-May-22

Send to DWP within 10 days after end of sampling period.