

Oregon  
Health  
Authority

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Aug	7.8	30	Y
2-Aug	7.7	32	Y
3-Aug	7.7	28	Y
4-Aug	7.7	30	Y
5-Aug	7.8	32	Y
6-Aug	7.7	30	Y
7-Aug	7.7	32	Y
8-Aug	7.7	30	Y
9-Aug	7.7	30	Y
10-Aug	7.7	30	Y
11-Aug	7.7	30	Y
12-Aug	7.8	30	Y
13-Aug	7.7	30	Y
14-Aug	7.7	30	Y
15-Aug	7.6	30	Y
16-Aug	7.7	30	Y
17-Aug	7.7	30	Y
18-Aug	7.7	30	Y
19-Aug	7.6	30	Y
20-Aug	7.7	32	Y
21-Aug	7.7	30	Y
22-Aug	7.6	32	Y
23-Aug	7.7	32	Y
24-Aug	7.6	30	Y
25-Aug	7.7	30	Y
26-Aug	7.8	30	Y
27-Aug	7.7	30	Y
28-Aug	7.8	30	Y
29-Aug	7.7	30	Y
30-Aug	7.8	30	Y
31-Aug	7.7	30	Y
<b>Total N's:</b>			<b>0</b>

(No = N = Excursion)

**ENTRY POINT**

**PWS: 41 00379**

**System Name:** Joint Water Commission

**Entry Point:** Finished Water Pump Stations

**Sample Period:** Aug-22  
Month / Year

**Number of excursions this month:**   
(count the number of days when any WQP was less than the minimum.)

**Total number of excursions during the previous 5 months:**   
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality Parameters as set by**

pH

Alk  (alkalinity)

PO4  (Othophosphate)

Other

**Print Name:** Zac Bertz

**Signature:** Zac Bertz

**Date:** 1-Sep-22

Digitally signed by Zac Bertz  
DN: cn=Zac Bertz, ou=Users, ou=Water, ou=COH, DC=w2k,  
DC=cl, DC=hillsboro, DC=or, DC=us  
Reason: I attest to the accuracy and integrity of this document  
Contact Info: 503-758-4446  
Date: 2022.09.01 12:55:12-0700

Send to DWP within 10 days after end of sampling period.