

Oregon  
Health  
Authority

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Sep	7.7	30	Y
2-Sep	7.6	30	Y
3-Sep	7.6	32	Y
4-Sep	7.7	30	Y
5-Sep	7.7	32	Y
6-Sep	7.6	30	Y
7-Sep	7.6	28	Y
8-Sep	7.7	28	Y
9-Sep	7.7	30	Y
10-Sep	7.7	30	Y
11-Sep	7.7	32	Y
12-Sep	7.6	32	Y
13-Sep	7.7	30	Y
14-Sep	7.8	32	Y
15-Sep	7.8	32	Y
16-Sep	7.7	30	Y
17-Sep	7.7	30	Y
18-Sep	7.7	30	Y
19-Sep	7.7	32	Y
20-Sep	7.7	30	Y
21-Sep	7.7	30	Y
22-Sep	7.7	32	Y
23-Sep	7.7	32	Y
24-Sep	7.7	30	Y
25-Sep	7.7	32	Y
26-Sep	7.7	30	Y
27-Sep	7.8	30	Y
28-Sep	7.8	32	Y
29-Sep	7.7	32	Y
30-Sep	7.8	32	Y
(No = N = Excursion) Total N's:			0

### ENTRY POINT

**PWS: 41 00379**

**System Name:** Joint Water Commission

**Entry Point:** Finished Water Pump Stations

**Sample Period:** Sep-22  
*Month / Year*

**Number of excursions this month:**   
*(count the number of days when any WQP was less than the minimum.)*

**Total number of excursions during the previous 5 months:**   
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)*

*for OHA use only*

**Minimum Water Quality Parameters as set by**

pH	<input style="width: 50px;" type="text" value="7.7"/>	
Alk	<input style="width: 50px;" type="text" value="30"/>	(alkalinity)
PO4	<input style="width: 50px;" type="text" value=""/>	(Orthophosphate)
Other	<input style="width: 50px;" type="text" value=""/>	(_____)

**Print Name:** Zac Bertz

**Signature:** Zac Bertz

**Date:** 3-Oct-22

Digitally signed by Zac Bertz  
DN: CN=Zac Bertz, OU=Users, OU=Water, OU=COH,  
DC=wr2, DC=ci, DC=illinois, DC=er, DC=us  
Reason: I attest to the accuracy and integrity of this document  
Contact Info: 503-758-4446  
Date: 2022.10.03 14:55:46-0700

Send to DWP within 10 days after end of sampling period.