

Oregon  
Health  
Authority

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Oct	7.7	34	Y
2-Oct	7.7	32	Y
3-Oct	7.7	32	Y
4-Oct	7.8	30	Y
5-Oct	7.8	30	Y
6-Oct	7.8	30	Y
7-Oct	7.7	30	Y
8-Oct	7.7	32	Y
9-Oct	7.7	30	Y
10-Oct	7.8	32	Y
11-Oct	7.8	30	Y
12-Oct	7.9	32	Y
13-Oct	7.7	32	Y
14-Oct	7.7	34	Y
15-Oct	7.6	34	Y
16-Oct	7.7	32	Y
17-Oct	7.6	32	Y
18-Oct	7.7	30	Y
19-Oct	7.8	32	Y
20-Oct	7.8	32	Y
21-Oct	7.9	32	Y
22-Oct	7.7	34	Y
23-Oct	7.7	34	Y
24-Oct	7.8	34	Y
25-Oct	7.7	34	Y
26-Oct	7.7	34	Y
27-Oct	7.6	34	Y
28-Oct	7.6	36	Y
29-Oct	7.7	38	Y
30-Oct	7.7	38	Y
31-Oct	7.7	36	Y

**ENTRY POINT**

**PWS:      41 00379**

**System Name:** Joint Water Commission

**Entry Point:** Finished Water Pump Stations

**Sample Period:** Oct-22  
Month / Year

**Number of excursions this month:**   
(count the number of days when any WQP was less than the minimum.)

**Total number of excursions during the previous 5 months:**   
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

*for OHA use only*

**Minimum Water Quality  
Parameters as set by**

pH	<input style="width: 50px;" type="text"/>	
Alk	<input style="width: 50px;" type="text"/>	(alkalinity)
PO4	<input style="width: 50px;" type="text"/>	(Orthophosphate)
Other	<input style="width: 50px;" type="text"/>	(_____)

**Print Name:** Zac Bertz

**Signature:** Zac Bertz

**Date:** 2-Nov-22

Digitally signed by Zac Bertz  
DN: CN=Zac Bertz, OU=Users, OU=Water, OU=COH, DC=w2k,  
DC=si, DC=hillsboro, DC=or, DC=us  
Reason: I am approving this document  
Contact Info: 503-758-4446  
Date: 2022.11.02 09:35:04-0700'

Send to DWP within 10 days after end of sampling period.

(No = N = Excursion)      **Total N's:**