

Oregon  
Health  
Authority

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Nov	7.7	38	Y
2-Nov	7.8	36	Y
3-Nov	7.6	38	Y
4-Nov	7.8	38	Y
5-Nov	7.7	28	Y
6-Nov	7.7	22	Y
7-Nov	7.7	28	Y
8-Nov	7.7	30	Y
9-Nov	7.7	32	Y
10-Nov	7.7	30	Y
11-Nov	7.8	32	Y
12-Nov	7.6	34	Y
13-Nov	7.7	34	Y
14-Nov	7.7	32	Y
15-Nov	7.7	34	Y
16-Nov	7.8	36	Y
17-Nov	7.7	36	Y
18-Nov	7.7	36	Y
19-Nov	7.7	38	Y
20-Nov	7.7	36	Y
21-Nov	7.7	36	Y
22-Nov	7.8	38	Y
23-Nov	7.7	38	Y
24-Nov	7.7	38	Y
25-Nov	7.8	38	Y
26-Nov	7.8	38	Y
27-Nov	7.7	36	Y
28-Nov	7.6	40	Y
29-Nov	7.6	34	Y
30-Nov	7.8	32	Y
(No = N = Excursion)	<b>Total N's:</b>	<b>0</b>	

### ENTRY POINT

**PWS: 41 00379**

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: Nov-22  
Month / Year

Number of excursions this month:   
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months:   
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

*for OHA use only*

**Minimum Water Quality  
Parameters as set by**


pH

Alk  (alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

Print Name: Chris Wilson

Signature: 

Date: 1-Dec-22

Send to DWP within 10 days after end of sampling period.