

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Jan	7.6	26	Y
2-Jan	7.7	28	Y
3-Jan	7.7	26	Y
4-Jan	7.7	30	Y
5-Jan	7.7	30	Y
6-Jan	7.7	30	Y
7-Jan	7.6	32	Y
8-Jan	7.7	32	Y
9-Jan	7.6	30	Y
10-Jan	7.6	28	Y
11-Jan	7.7	28	Y
12-Jan	7.8	26	Y
13-Jan	7.7	30	Y
14-Jan	7.7	30	Y
15-Jan	7.9	30	Y
16-Jan	7.6	28	Y
17-Jan	7.8	28	Y
18-Jan	7.7	30	Y
19-Jan	7.7	30	Y
20-Jan	7.8	32	Y
21-Jan	7.7	30	Y
22-Jan	7.7	30	Y
23-Jan	7.7	30	Y
24-Jan	7.7	30	Y
25-Jan	7.7	32	Y
26-Jan	7.7	32	Y
27-Jan	7.8	36	Y
28-Jan	7.7	34	Y
29-Jan	7.8	34	Y
30-Jan	7.8	34	Y
31-Jan	7.7	32	Y

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: EP-A (Finished Water Pump Station)

Sample Period: January-2022
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk (alkalinity)

PO4 (Othophosphate)

Other ()

Print Name: Zac Bertz

Signature: Zac Bertz

Date: 2/6/2023

Digitally signed by Zac Bertz
DN: CN=Zac Bertz, OU=Users, OU=Water, OU=COH, DC=w2k, DC=oh.
DC=illaboro, DC=or, DC=us
Reason: I attest to the accuracy and integrity of this document
Contact info: 503-738-4446
Date: 2023.02.06 15:20:01-0800'

Send to DWP within 10 days after end of sampling period.

(No = N = Excursion) **Total N's:** 0