Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkilinity	Minimums met? Y / N
1-Feb	7.8	32	Y
2-Feb	7.7	32	Y
3-Feb	7.7	32	Y
4-Feb	7.7	34	Y
5-Feb	7.8	32	Y
6-Feb	7.7	34	Y
7-Feb	7.8	32	Y
8-Feb	7.7	32	Y
9-Feb	7.8	32	Y
10-Feb	7.6	32	Y
11-Feb	7.7	30	Y
12-Feb	7.7	32	Y
13-Feb	7.8	34	Y
14-Feb	7.7	34	Y
15-Feb	7.7	34	Y
16-Feb	7.7	32	Y
17-Feb	7.7	32	Y
18-Feb	7.7	34	Y
19-Feb	7.7	34	Y
20-Feb	7.8	34	Y
21-Feb	7.8	34	Y
22-Feb	7.8	34	Y
23-Feb	7.6	32	Y
24-Feb	7.7	32	Y
25-Feb	7.7	32	Y
26-Feb	7.6	34	Y
27-Feb	7.6	32	Y
28-Feb	7.6	32	Y
(No = N = Excursion)		**Total N's:**	0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission
Entry Point: Finished Water Pump Stations
Sample Period:. Feb-23
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk		*(alkalinity)*
PO4		*(Othophosphate)*
Other		*(_____)*

Print Name: Zac Bertz

Signature: Zac Bertz
Digitally signed by Zac Bertz
DN: CN=Zac Bertz, OU=Users, OU=Water, OU=COH, DC=w2k, DC=ci, DC=hillsboro, DC=or, DC=us
Reason: I attest to the accuracy and integrity of this document
Contact Info: 503-758-4446
Date: 2023.03.03 08:51:18-08'00'

Date: 3-Mar-23

Send to DWP within 10 days after end of sampling period.

Notes: OHA Drinking Water Program, PO Box 14350. Portland, OR 97293-0350
Phone (971) 673-0405 website: http://healthoregon.gov/dwp/