

Oregon  
Health  
Authority

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Mar	7.7	32	Y
2-Mar	7.8	34	Y
3-Mar	7.8	34	Y
4-Mar	7.7	32	Y
5-Mar	7.7	28	Y
6-Mar	7.8	24	Y
7-Mar	7.7	30	Y
8-Mar	7.7	30	Y
9-Mar	7.8	30	Y
10-Mar	7.7	28	Y
11-Mar	7.7	26	Y
12-Mar	7.6	30	Y
13-Mar	7.7	30	Y
14-Mar	7.7	30	Y
15-Mar	7.7	28	Y
16-Mar	7.6	30	Y
17-Mar	7.6	30	Y
18-Mar	7.7	32	Y
19-Mar	7.7	30	Y
20-Mar	7.7	30	Y
21-Mar	7.7	30	Y
22-Mar	7.8	28	Y
23-Mar	7.7	30	Y
24-Mar	7.7	30	Y
25-Mar	7.7	26	Y
26-Mar	7.8	28	Y
27-Mar	7.7	30	Y
28-Mar	7.7	30	Y
29-Mar	7.7	30	Y
30-Mar	7.8	28	Y
Notes:	7.7	30	Y
(No = N = Excursion)	<b>Total N's:</b>	<b>0</b>	

**ENTRY POINT**

**PWS: 41.0 00379**

**System Name:** Joint Water Commission

**Entry Point:** Finished Water Pump Stations

**Sample Period:** Mar-23  
Month / Year

**Number of excursions this month:**   
(count the number of days when any WQP was less than the minimum.)

**Total number of excursions during the previous 5 months:**   
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality Parameters as set by**

pH	<input type="text" value=""/>	
Alk	<input type="text" value=""/>	(alkalinity)
PO4	<input type="text" value=""/>	(Orthophosphate)
Other	<input type="text" value=""/>	(_____)

**Print Name:** Zac Bertz

**Signature:** Zac Bertz

**Date:** 11-Apr-23

Digitally signed by Zac Bertz  
DN: CN=Zac Bertz, OU=Users, OU=Water, OU=COH, DC=w2k,  
DC=ell, DC=hillstoro, DC=or, DC=us  
Reason: I attest to the accuracy and integrity of this document  
Contact Info: 503-758-4446  
Date: 2023.04.11 13:45:22-0700

Send to DWP within 10 days after end of sampling period.