

Oregon
Health
Authority

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Apr	7.6	30	Y
2-Apr	7.7	28	Y
3-Apr	7.7	28	Y
4-Apr	7.7	30	Y
5-Apr	7.7	30	Y
6-Apr	7.8	28	Y
7-Apr	7.6	30	Y
8-Apr	7.7	30	Y
9-Apr	7.8	28	Y
10-Apr	7.7	28	Y
11-Apr	7.3	24	Y
12-Apr	7.7	30	Y
13-Apr	7.7	28	Y
14-Apr	7.7	28	Y
15-Apr	7.7	30	Y
16-Apr	7.7	30	Y
17-Apr	7.7	28	Y
18-Apr	7.7	30	Y
19-Apr	7.7	30	Y
20-Apr	7.7	28	Y
21-Apr	7.7	30	Y
22-Apr	7.6	30	Y
23-Apr	7.7	30	Y
24-Apr	7.7	30	Y
25-Apr	7.6	30	Y
26-Apr	7.7	28	Y
27-Apr	7.7	30	Y
28-Apr	7.7	30	Y
29-Apr	7.7	30	Y
30-Apr	7.7	32	Y
(No = N = Excursion)	Total N's:	0	

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: April-2023
Month / Year

Number of excursions this month:
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality Parameters as set by


pH

Alk (alkalinity)

PO4 (Othophosphate)

Other

Print Name: Zac Bertz

Signature:  **Zac Bertz**

Date: 1-May-23

Send to DWP within 10 days after end of sampling period.