

Oregon
Health
Authority

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-May	7.8	32	Y
2-May	7.7	34	Y
3-May	7.4	32	Y
4-May	7.7	30	Y
5-May	7.8	34	Y
6-May	7.7	32	Y
7-May	7.7	34	Y
8-May	7.7	34	Y
9-May	7.7	36	Y
10-May	7.7	36	Y
11-May	7.7	36	Y
12-May	7.6	36	Y
13-May	7.7	36	Y
14-May	7.6	38	Y
15-May	7.6	38	Y
16-May	7.6	38	Y
17-May	7.5	38	Y
18-May	7.6	38	Y
19-May	7.7	40	Y
20-May	7.8	38	Y
21-May	7.7	38	Y
22-May	7.7	38	Y
23-May	7.7	38	Y
24-May	7.7	40	Y
25-May	7.7	38	Y
26-May	7.6	36	Y
27-May	7.7	38	Y
28-May	7.8	38	Y
29-May	7.7	34	Y
30-May	7.7	36	Y
31-May	7.7	36	Y
(No = N = Excursion) Total N's:			0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: Finished Water Pump Station

Sample Period: May-23
Month / Year

Number of excursions this month:
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH	7.2	
Alk		<i>(alkalinity)</i>
PO4		<i>(Othophosphate)</i>
Other		<i>(_____)</i>

Print Name: Zac Bertz

Signature: Zac Bertz

Date: 1-Jun-23

Send to DWP within 10 days after end of sampling period.

Digitally signed by Zac Bertz,
DN: cn=Zac Bertz, ou=Users, ou=Water, ou=COH, dc=w2k,
dc=cl, dc=hillsboro, dc=or, dc=us
Reason: I attest to the accuracy and integrity of this document
Contact info: 503-758-4446
Date: 2023.06.01 09:22:36-07'00'