

Oregon  
Health  
Authority

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Jun	7.8	34	Y
2-Jun	7.8	32	Y
3-Jun	7.7	32	Y
4-Jun	7.8	32	Y
5-Jun	7.6	32	Y
6-Jun	7.6	30	Y
7-Jun	7.7	28	Y
8-Jun	7.6	30	Y
9-Jun	7.6	30	Y
10-Jun	7.8	32	Y
11-Jun	7.7	32	Y
12-Jun	7.7	30	Y
13-Jun	7.7	32	Y
14-Jun	7.7	30	Y
15-Jun	7.8	32	Y
16-Jun	7.7	32	Y
17-Jun	7.6	32	Y
18-Jun	7.7	32	Y
19-Jun	7.7	32	Y
20-Jun	7.7	32	Y
21-Jun	7.7	32	Y
22-Jun	7.7	32	Y
23-Jun	7.7	32	Y
24-Jun	7.7	32	Y
25-Jun	7.7	30	Y
26-Jun	7.7	30	Y
27-Jun	7.7	32	Y
28-Jun	7.7	30	Y
29-Jun	7.6	32	Y
30-Jun	7.7	30	Y
(No = N = Excursion)	<b>Total N's:</b>	<b>0</b>	

### ENTRY POINT

**PWS: 41 00379**

**System Name:** Joint Water Commission

**Entry Point:** Finished Water Pump Station

**Sample Period:** Jun-23  
*Month / Year*

**Number of excursions this month:**   
*(count the number of days when any WQP was less than the minimum.)*

**Total number of excursions during the previous 5 months:**   
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)*

*for OHA use only*

**Minimum Water Quality Parameters as set by**

pH

Alk  *(alkalinity)*

PO4  *(Othophosphate)*

Other  *(\_\_\_\_\_)*

**Print Name:** Zac Bertz

**Signature:** Zac Bertz

**Date:** 6-Jul-23

Send to DWP within 10 days after end of sampling period.

Digitally signed by Zac Bertz  
DN: CN=Zac Bertz, OU=Users, OU=Water, OU=COH, DC=w2k, DC=c,  
DC=hillsboro, DC=or, DC=us  
Reason: I attest to the accuracy and integrity of this document  
Contact info: 503-758-4446  
Date: 2023.07.06 09:07:18 -07'00'