

Oregon
Health
Authority

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Jul	7.7	30	Y
2-Jul	7.7	30	Y
3-Jul	7.6	28	Y
4-Jul	7.7	28	Y
5-Jul	7.7	28	Y
6-Jul	7.7	28	Y
7-Jul	7.8	28	Y
8-Jul	7.7	30	Y
9-Jul	7.7	30	Y
10-Jul	7.7	28	Y
11-Jul	7.7	30	Y
12-Jul	7.7	30	Y
13-Jul	7.7	30	Y
14-Jul	7.7	30	Y
15-Jul	7.7	30	Y
16-Jul	7.7	30	Y
17-Jul	7.7	30	Y
18-Jul	7.7	30	Y
19-Jul	7.7	30	Y
20-Jul	7.7	30	Y
21-Jul	7.7	30	Y
22-Jul	7.7	28	Y
23-Jul	7.6	28	Y
24-Jul	7.7	28	Y
25-Jul	7.7	30	Y
26-Jul	7.7	30	Y
27-Jul	7.6	30	Y
28-Jul	7.7	30	Y
29-Jul	7.8	30	Y
30-Jul	7.8	30	Y
31-Jul	7.7	28	Y
(No = N = Excursion)	Total N's:	0	

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: Jul-23
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality Parameters as set by


pH 7.2

Alk (alkalinity)

PO4 (Othophosphate)

Other (_____)

Print Name: Zac Bertz

Signature: 

Date: 2-Aug-23

Send to DWP within 10 days after end of sampling period.