

Oregon
Health
Authority

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average	FW	Minimums
	FW pH	FW Alkalinity	met? Y / N
1-Aug	7.6	28	Y
2-Aug	7.7	28	Y
3-Aug	7.7	28	Y
4-Aug	7.7	28	Y
5-Aug	7.8	28	Y
6-Aug	7.7	28	Y
7-Aug	7.7	26	Y
8-Aug	7.7	30	Y
9-Aug	7.7	28	Y
10-Aug	7.8	28	Y
11-Aug	7.7	28	Y
12-Aug	7.7	28	Y
13-Aug	7.6	28	Y
14-Aug	7.6	28	Y
15-Aug	7.6	28	Y
16-Aug	7.7	28	Y
17-Aug	7.7	28	Y
18-Aug	7.7	28	Y
19-Aug	7.7	28	Y
20-Aug	7.7	28	Y
21-Aug	7.7	28	Y
22-Aug	7.7	28	Y
23-Aug	7.8	28	Y
24-Aug	7.8	28	Y
25-Aug	7.6	28	Y
26-Aug	7.7	28	Y
27-Aug	7.7	28	Y
28-Aug	7.7	30	Y
29-Aug	7.8	30	Y
30-Aug	7.7	28	Y
31-Aug	7.7	28	Y
Total N's:			0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: Aug-23
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)


Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text"/>	
Alk	<input type="text"/>	(alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: Zac Bertz

Signature: 

Date: 5-Sep-23

Send to DWP within 10 days after end of sampling period.