

Oregon
Health
Authority

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Oct	7.8	32	Y
2-Oct	7.8	34	Y
3-Oct	7.7	34	Y
4-Oct	7.6	34	Y
5-Oct	7.7	34	Y
6-Oct	7.8	34	Y
7-Oct	7.8	34	Y
8-Oct	7.7	34	Y
9-Oct	7.8	34	Y
10-Oct	7.8	34	Y
11-Oct	7.6	34	Y
12-Oct	7.6	34	Y
13-Oct	7.7	34	Y
14-Oct	7.8	32	Y
15-Oct	7.7	34	Y
16-Oct	7.7	34	Y
17-Oct	7.6	34	Y
18-Oct	7.6	36	Y
19-Oct	7.8	38	Y
20-Oct	7.8	36	Y
21-Oct	7.7	36	Y
22-Oct	7.7	36	Y
23-Oct	7.7	36	Y
24-Oct	7.7	34	Y
25-Oct	7.7	36	Y
26-Oct	7.6	34	Y
27-Oct	7.7	34	Y
28-Oct	7.8	36	Y
29-Oct	7.7	36	Y
30-Oct	7.7	36	Y
31-Oct	7.8	34	Y
(No = N = Excursion)	Total N's:	0	

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: Oct-23
Month / Year

Number of excursions this month:
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH

Alk *(alkalinity)*

PO4 *(Othophosphate)*

Other *(_____)*

Print Name: Zac Bertz

Signature: 

Date: 1-Nov-23

Send to DWP within 10 days after end of sampling period.