

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Dec	7.7	40	Y
2-Dec	7.7	34	Y
3-Dec	7.6	30	Y
4-Dec	7.6	30	Y
5-Dec	7.8	26	Y
6-Dec	7.7	26	Y
7-Dec	7.7	24	Y
8-Dec	7.7	26	Y
9-Dec	7.7	28	Y
10-Dec	7.7	28	Y
11-Dec	7.6	26	Y
12-Dec	7.7	28	Y
13-Dec	7.6	28	Y
14-Dec	7.7	32	Y
15-Dec	7.7	32	Y
16-Dec	7.6	36	Y
17-Dec	7.8	38	Y
18-Dec	7.8	38	Y
19-Dec	7.8	36	Y
20-Dec	7.7	36	Y
21-Dec	7.7	36	Y
22-Dec	7.8	34	Y
23-Dec	7.7	34	Y
24-Dec	7.7	34	Y
25-Dec	7.7	34	Y
26-Dec	7.7	32	Y
27-Dec	7.7	32	Y
28-Dec	7.7	32	Y
29-Dec	7.6	34	Y
30-Dec	7.8	34	Y
31-Dec	7.7	34	Y
(No = N = Excursion)	Total N's:		0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: Dec-23
Month / Year

Number of excursions this month:
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Zachary Bertz

Signature: 

Date: 1/4/2024

Send to DWP within 10 days after end of sampling period.