

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Jan	7.8	34	Y
2-Jan	7.7	34	Y
3-Jan	7.7	32	Y
4-Jan	7.7	32	Y
5-Jan	7.7	32	Y
6-Jan	7.7	28	Y
7-Jan	7.6	30	Y
8-Jan	7.8	28	Y
9-Jan	7.7	30	Y
10-Jan	7.7	28	Y
11-Jan	7.6	28	Y
12-Jan	7.7	30	Y
13-Jan	7.8	28	Y
14-Jan	7.7	30	Y
15-Jan	7.7	32	Y
16-Jan	7.8	32	Y
17-Jan	7.7	30	Y
18-Jan	7.6	28	Y
19-Jan	7.6	28	Y
20-Jan	7.7	26	Y
21-Jan	7.7	26	Y
22-Jan	7.7	24	Y
23-Jan	7.6	28	Y
24-Jan	7.9	28	Y
25-Jan	7.7	24	Y
26-Jan	7.7	28	Y
27-Jan	7.7	26	Y
28-Jan	7.5	26	Y
29-Jan	7.7	26	Y
30-Jan	7.7	26	Y
31-Jan	7.7	28	Y
(No = N = Excursion)	Total N's:	0	

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: January-2024
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2

Alk *(alkalinity)*

PO4 *(Othophosphate)*

Other *(_____)*

Print Name: Zachary Bertz

Signature: DocuSigned by:
Zac Bertz

Date: 2/2/2024

Send to DWP within 10 days after end of sampling period.