

Oregon  
Health  
Authority

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Feb	7.8	28	Y
2-Feb	7.7	28	Y
3-Feb	7.8	26	Y
4-Feb	7.7	28	Y
5-Feb	7.8	28	Y
6-Feb	7.6	32	Y
7-Feb	7.7	36	Y
8-Feb	7.7	38	Y
9-Feb	7.8	38	Y
10-Feb	7.7	38	Y
11-Feb	7.7	38	Y
12-Feb	7.7	38	Y
13-Feb	7.7	38	Y
14-Feb	7.6	34	Y
15-Feb	7.6	30	Y
16-Feb	7.7	32	Y
17-Feb	7.7	32	Y
18-Feb	7.7	30	Y
19-Feb	7.7	32	Y
20-Feb	7.7	32	Y
21-Feb	7.8	34	Y
22-Feb	7.7	34	Y
23-Feb	7.7	34	Y
24-Feb	7.7	32	Y
25-Feb	7.7	32	Y
26-Feb	7.7	32	Y
27-Feb	7.7	30	Y
28-Feb	7.7	30	Y
29-Feb	7.7	20	Y
<b>Total N's:</b>			<b>0</b>

(No = N = Excursion)

### ENTRY POINT

**PWS: 41 00379**

**System Name:** Joint Water Commission

**Entry Point:** Finished Water Pump Stations

**Sample Period:** February 2024  
*Month / Year*

**Number of excursions this month:**   
*(count the number of days when any WQP was less than the minimum.)*

**Total number of excursions during the previous 5 months:**   
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)*

*for OHA use only*

**Minimum Water Quality Parameters as set by**


pH

Alk  *(alkalinity)*

PO4  *(Othophosphate)*

Other  *(\_\_\_\_\_)*

**Print Name:** Zachary Bertz

**Signature:** 

**Date:** 3/5/2024

Send to DWP within 10 days after end of sampling period.

Notes: OHA Drinking Water Program, PO Box 14350. Portland, OR 97293-0350  
Phone (971) 673-0405 website: <http://healthoregon.gov/dwp/>