

Oregon  
Health  
Authority

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-Apr	7.7	32	Y
2-Apr	7.7	32	Y
3-Apr	7.7	32	Y
4-Apr	7.7	32	Y
5-Apr	7.7	32	Y
6-Apr	7.7	34	Y
7-Apr	7.8	32	Y
8-Apr	7.7	34	Y
9-Apr	7.6	34	Y
10-Apr	7.8	34	Y
11-Apr	7.8	34	Y
12-Apr	7.8	36	Y
13-Apr	7.7	36	Y
14-Apr	7.7	36	Y
15-Apr	7.7	36	Y
16-Apr	7.7	38	Y
17-Apr	7.8	38	Y
18-Apr	7.8	40	Y
19-Apr	7.9	40	Y
20-Apr	7.9	40	Y
21-Apr	7.8	42	Y
22-Apr	7.7	38	Y
23-Apr	7.8	40	Y
24-Apr	7.8	40	Y
25-Apr	7.7	38	Y
26-Apr	7.7	38	Y
27-Apr	7.7	36	Y
28-Apr	7.7	34	Y
29-Apr	7.7	36	Y
30-Apr	7.7	36	Y
(No = N = Excursion) Total N's:			0

### ENTRY POINT

**PWS: 41 00379**

System Name: Joint Water Commission

Entry Point: Finished Water Pump Stations

Sample Period: April 2024  
*Month / Year*

Number of excursions this month: 0  
*(count the number of days when any WQP was less than the minimum.)*

Total number of excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)*

*for OHA use only*

**Minimum Water Quality Parameters as set by**

pH 7.2

Alk  *(alkalinity)*

PO4  *(Orthophosphate)*

Other  *(\_\_\_\_\_)*

Print Name: Zac Bertz

DocuSigned by:  
Signature: *Zachary Bertz*

Date: 5/1/2024

Send to DWP within 10 days after end of sampling period.