

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
1-May	7.7	32	Y
2-May	7.7	32	Y
3-May	7.7	30	Y
4-May	7.8	30	Y
5-May	7.6	32	Y
6-May	7.7	32	Y
7-May	7.7	32	Y
8-May	7.8	32	Y
9-May	7.7	34	Y
10-May	7.7	34	Y
11-May	7.7	34	Y
12-May	7.7	34	Y
13-May	7.7	34	Y
14-May	7.7	36	Y
15-May	7.7	36	Y
16-May	7.7	36	Y
17-May	7.7	36	Y
18-May	7.8	36	Y
19-May	7.8	38	Y
20-May	7.8	34	Y
21-May	7.7	38	Y
22-May	7.8	38	Y
23-May	7.7	38	Y
24-May	7.8	38	Y
25-May	7.7	38	Y
26-May	7.7	38	Y
27-May	7.7	38	Y
28-May	7.7	38	Y
29-May	7.7	38	Y
30-May	7.8	38	Y
31-May	7.8	38	Y
Total N's:			0

(No = N = Excursion)

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission
Entry Point: Finished Water Pump Stations
Sample Period: May-24
Month / Year

Number of excursions this month:

(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months:


(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	<i>(alkalinity)</i>
PO4	<input type="text"/>	<i>(Orthophosphate)</i>
Other	<input type="text"/>	<i>(_____)</i>

Print Name: Zac Bertz

Signature: 

Date: 6/6/2024

Send to DWP within 10 days after end of sampling period.