

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average		Minimums met? Y / N
	FW pH	FW Alkalinity	
6/1	7.66	38	Y
6/2	7.73	38	Y
6/3	7.72	34	Y
6/4	7.69	36	Y
6/5	7.78	36	Y
6/6	7.73	36	Y
6/7	7.66	36	Y
6/8	7.65	36	Y
6/9	7.71	36	Y
6/10	7.68	38	Y
6/11	7.68	36	Y
6/12	7.73	38	Y
6/13	7.76	36	Y
6/14	7.81	34	Y
6/15	7.79	34	Y
6/16	7.74	34	Y
6/17	7.78	34	Y
6/18	7.75	34	Y
6/19	7.75	34	Y
6/20	7.69	32	Y
6/21	7.69	32	Y
6/22	7.72	32	Y
6/23	7.74	32	Y
6/24	7.75	30	Y
6/25	7.75	32	Y
6/26	7.74	30	Y
6/27	7.77	34	Y
6/28	7.84	32	Y
6/29	7.77	32	Y
6/30	7.69	34	Y

(No = N = Excursion) **Total N's:** 0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: EP-A Finished Water Pump Stations

Sample Period: June 2024
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	<i>(alkalinity)</i>
PO4	<input type="text"/>	<i>(Othophosphate)</i>
Other	<input type="text"/>	<i>(_____)</i>

Print Name: Zac Bertz

Signature: DocuSigned by:
Zac Bertz

Date: 7/2/2024

Send to DWP within 10 days after end of sampling period.