

Oregon  
Health  
Authority

Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

DATE	Average		Minimums met? Y/N
	FW pH	FW Alkalinity	
7/1	7.73	32	Y
7/2	7.76	30	Y
7/3	7.77	30	Y
7/4	7.71	28	Y
7/5	7.70	28	Y
7/6	7.69	28	Y
7/7	7.71	30	Y
7/8	7.70	30	Y
7/9	7.68	30	Y
7/10	7.72	28	Y
7/11	7.77	28	Y
7/12	7.71	28	Y
7/13	7.75	28	Y
7/14	7.73	28	Y
7/15	7.76	30	Y
7/16	7.75	28	Y
7/17	7.73	28	Y
7/18	7.72	28	Y
7/19	7.71	28	Y
7/20	7.71	28	Y
7/21	7.71	30	Y
7/22	7.72	28	Y
7/23	7.72	30	Y
7/24	7.72	30	Y
7/25	7.75	28	Y
7/26	7.72	30	Y
7/27	7.67	30	Y
7/28	7.66	30	Y
7/29	7.66	30	Y
7/30	7.64	30	Y
7/31	7.69	30	Y
(No = N = Excursion) Total N's:			0

**ENTRY POINT**

**PWS: 41 00379**

**System Name:** Joint Water Commission

**Entry Point:** EP-A Finished Water Pump Stations

**Sample Period:** July 2024  
*Month / Year*

**Number of excursions this month:** 0  
*(count the number of days when any WQP was less than the minimum.)*

**Total number of excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)*

*for OHA use only*

**Minimum Water Quality Parameters as set by**

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	<i>(alkalinity)</i>
PO4	<input type="text"/>	<i>(Othophosphate)</i>
Other	<input type="text"/>	<i>(_____)</i>

**Print Name:** Todd Evers

**Signature:** 

**Date:** 8/5/2024

Send to DWP within 10 days after end of sampling period.