

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

DATE	Average		Minimums met? Y / N
	FW pH	FW Alkalinity	
8/1	7.69	28	Y
8/2	7.65	28	Y
8/3	7.69	28	Y
8/4	7.70	30	Y
8/5	7.68	30	Y
8/6	7.75	30	Y
8/7	7.77	28	Y
8/8	7.69	30	Y
8/9	7.73	30	Y
8/10	7.76	28	Y
8/11	7.82	28	Y
8/12	7.71	28	Y
8/13	7.60	28	Y
8/14	7.63	28	Y
8/15	7.69	28	Y
8/16	7.73	28	Y
8/17	7.70	28	Y
8/18	7.65	30	Y
8/19	7.75	28	Y
8/20	7.77	28	Y
8/21	7.81	30	Y
8/22	7.76	28	Y
8/23	7.71	30	Y
8/24	7.60	28	Y
8/25	7.73	30	Y
8/26	7.71	30	Y
8/27	7.78	30	Y
8/28	7.77	30	Y
8/29	7.70	30	Y
8/30	7.72	30	Y
8/31	7.70	30	Y
(No = N = Excursion) Total N's:			0

**ENTRY POINT**

**PWS: 41 00379**

**System Name:** Joint Water Commission

**Entry Point:** EP-A Finished Water Pump Stations

**Sample Period:** August 2024  
*Month / Year*

**Number of excursions this month:** 0  
*(count the number of days when any WQP was less than the minimum.)*


**Total number of excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)*

*for OHA use only*

**Minimum Water Quality Parameters as set by**

pH	<input style="width: 90%;" type="text" value="7.2"/>	
Alk	<input style="width: 90%;" type="text"/>	<i>(alkalinity)</i>
PO4	<input style="width: 90%;" type="text"/>	<i>(Othophosphate)</i>
Other	<input style="width: 90%;" type="text"/>	<i>(_____)</i>

**Print Name:** Todd Evers

**Signature:** 

**Date:** 9/4/2024

Send to DWP within 10 days after end of sampling period.