

Oregon
Health
Authority

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average		Minimums met? Y / N
	FW pH	FW Alkalinity	
9/1	7.73	30	Y
9/2	7.74	30	Y
9/3	7.75	30	Y
9/4	7.68	30	Y
9/5	7.64	28	Y
9/6	7.66	28	Y
9/7	7.70	28	Y
9/8	7.68	28	Y
9/9	7.75	30	Y
9/10	7.63	30	Y
9/11	7.76	30	Y
9/12	7.69	30	Y
9/13	7.73	30	Y
9/14	7.70	30	Y
9/15	7.73	30	Y
9/16	7.71	30	Y
9/17	7.78	30	Y
9/18	7.67	30	Y
9/19	7.72	30	Y
9/20	7.63	30	Y
9/21	7.69	30	Y
9/22	7.64	32	Y
9/23	7.65	30	Y
9/24	7.63	28	Y
9/25	7.72	30	Y
9/26	7.74	30	Y
9/27	7.75	30	Y
9/28	7.77	30	Y
9/29	7.71	30	Y
9/30	7.80	30	Y
(No = N = Excursion) Total N's:			0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: EP-A Finished Water Pump Stations

Sample Period: September 2024
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)


Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality Parameters as set by

pH	<u>7.2</u>	
Alk	<u> </u>	<i>(alkalinity)</i>
PO4	<u> </u>	<i>(Othophosphate)</i>
Other	<u> </u>	<i>()</i>

Print Name: Todd Evers

Signature: 

Date: 10/2/2024

Send to DWP within 10 days after end of sampling period.