

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average		Minimums met? Y/N
	FW pH	FW Alkalinity	
10/1	7.73	30	Y
10/2	7.75	28	Y
10/3	7.59	28	Y
10/4	7.61	30	Y
10/5	7.64	30	Y
10/6	7.68	30	Y
10/7	7.63	32	Y
10/8	7.66	30	Y
10/9	7.63	30	Y
10/10	7.74	30	Y
10/11	7.78	32	Y
10/12	7.75	32	Y
10/13	7.74	30	Y
10/14	7.74	32	Y
10/15	7.71	32	Y
10/16	7.79	32	Y
10/17	7.65	32	Y
10/18	7.65	34	Y
10/19	7.72	32	Y
10/20	7.73	32	Y
10/21	7.66	34	Y
10/22	7.64	36	Y
10/23	7.69	32	Y
10/24	7.78	32	Y
10/25	7.74	32	Y
10/26	7.71	32	Y
10/27	7.67	34	Y
10/28	7.78	34	Y
10/29	7.76	34	Y
10/30	7.75	34	Y
10/31	7.71	36	Y
(No = N = Excursion) Total N's:			0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: EP-A Finished Water Pump Stations

Sample Period: October 2024
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)


Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	<i>(alkalinity)</i>
PO4	<input type="text"/>	<i>(Othophosphate)</i>
Other	<input type="text"/>	<i>(_____)</i>

Print Name: Todd Evers

Signature: 

Date: 11/5/2024

Send to DWP within 10 days after end of sampling period.