

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

DATE	Average		Minimums met? Y / N
	FW pH	FW Alkalinity	
11/1	7.64	36	Y
11/2	7.50	28	Y
11/3	7.65	34	Y
11/4	7.73	36	Y
11/5	7.70	36	Y
11/6	7.71	34	Y
11/7	7.72	36	Y
11/8	7.75	36	Y
11/9	7.74	36	Y
11/10	7.77	38	Y
11/11	7.74	40	Y
11/12	7.70	38	Y
11/13	7.80	36	Y
11/14	7.73	26	Y
11/15	7.70	28	Y
11/16	7.61	28	Y
11/17	7.86	28	Y
11/18	7.78	28	Y
11/19	7.73	26	Y
11/20	7.75	22	Y
11/21	7.83	24	Y
11/22	7.73	24	Y
11/23	7.73	26	Y
11/24	7.79	26	Y
11/25	7.72	24	Y
11/26	7.69	28	Y
11/27	7.68	30	Y
11/28	7.76	34	Y
11/29	7.74	34	Y
11/30	7.87	34	Y
(No = N = Excursion) Total N's:			0

**ENTRY POINT**

**PWS: 41 00379**

**System Name:** Joint Water Commission

**Entry Point:** EP-A Finished Water Pump Stations

**Sample Period:** November 2024  
*Month / Year*

**Number of excursions this month:** 0  
*(count the number of days when any WQP was less than the minimum.)*


**Total number of excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)*

*for OHA use only*

**Minimum Water Quality Parameters as set by**

pH	<input style="width: 90%;" type="text" value="7.2"/>	
Alk	<input style="width: 90%;" type="text"/>	<i>(alkalinity)</i>
PO4	<input style="width: 90%;" type="text"/>	<i>(Othophosphate)</i>
Other	<input style="width: 90%;" type="text"/>	<i>(_____)</i>

**Print Name:** Todd Evers

**Signature:** 

**Date:** 12/4/2024

Send to DWP within 10 days after end of sampling period.