

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average		Minimums met? Y/N
	FW pH	FW Alkalinity	
12/1	7.78	34	Y
12/2	7.83	34	Y
12/3	7.78	36	Y
12/4	7.69	34	Y
12/5	7.74	36	Y
12/6	7.70	36	Y
12/7	7.73	38	Y
12/8	7.73	38	Y
12/9	7.63	34	Y
12/10	7.71	34	Y
12/11	7.73	38	Y
12/12	7.75	34	Y
12/13	7.76	34	Y
12/14	7.77	30	Y
12/15	7.65	30	Y
12/16	7.66	24	Y
12/17	7.70	24	Y
12/18	7.66	24	Y
12/19	7.71	26	Y
12/20	7.74	30	Y
12/21	7.75	30	Y
12/22	7.74	30	Y
12/23	7.73	30	Y
12/24	7.73	30	Y
12/25	7.74	30	Y
12/26	7.74	24	Y
12/27	7.74	24	Y
12/28	7.76	26	Y
12/29	7.70	22	Y
12/30	7.69	24	Y
12/31	7.70	30	Y
(No = N = Excursion) Total N's:			0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: EP-A Finished Water Pump Stations

Sample Period: December 2024
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)


Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input style="width: 90%;" type="text" value="7.2"/>	
Alk	<input style="width: 90%;" type="text"/>	<i>(alkalinity)</i>
PO4	<input style="width: 90%;" type="text"/>	<i>(Othophosphate)</i>
Other	<input style="width: 90%;" type="text"/>	<i>(_____)</i>

Print Name: Todd Evers

Signature: 

Date: 1/2/2025

Send to DWP within 10 days after end of sampling period.