

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average		Minimums met? Y/N
	FW pH	FW Alkalinity	
1/1	7.77	29	Y
1/2	7.75	32	Y
1/3	7.74	30	Y
1/4	7.68	30	Y
1/5	7.68	28	Y
1/6	7.61	30	Y
1/7	7.67	30	Y
1/8	7.69	28	Y
1/9	7.78	24	Y
1/10	7.75	28	Y
1/11	7.72	24	Y
1/12	7.74	32	Y
1/13	7.76	26	Y
1/14	7.76	32	Y
1/15	7.66	32	Y
1/16	7.58	32	Y
1/17	7.73	34	Y
1/18	7.69	36	Y
1/19	7.67	32	Y
1/20	7.73	38	Y
1/21	7.68	36	Y
1/22	7.75	32	Y
1/23	7.77	38	Y
1/24	7.80	38	Y
1/25	7.69	38	Y
1/26	7.69	38	Y
1/27	7.75	38	Y
1/28	7.74	38	Y
1/29	7.67	38	Y
1/30	7.73	38	Y
1/31	7.70	38	Y
(No = N = Excursion) Total N's:			0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: EP-A Finished Water Pump Stations

Sample Period: January 2025
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)


Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input style="width: 90%;" type="text" value="7.2"/>	
Alk	<input style="width: 90%;" type="text"/>	<i>(alkalinity)</i>
PO4	<input style="width: 90%;" type="text"/>	<i>(Othophosphate)</i>
Other	<input style="width: 90%;" type="text"/>	<i>(_____)</i>

Print Name: Todd Evers

Signature: 

Date: 2/3/2025

Send to DWP within 10 days after end of sampling period.