

Oregon
Health
Authority

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average		Minimums met? Y / N
	FW pH	FW Alkalinity	
2/1	7.69	36	Y
2/2	7.77	34	Y
2/3	7.74	36	Y
2/4	7.67	36	Y
2/5	7.77	38	Y
2/6	7.72	34	Y
2/7	7.73	32	Y
2/8	7.76	34	Y
2/9	7.68	32	Y
2/10	7.61	34	Y
2/11	7.69	36	Y
2/12	7.71	36	Y
2/13	7.63	34	Y
2/14	7.67	34	Y
2/15	7.68	34	Y
2/16	7.63	36	Y
2/17	7.58	30	Y
2/18	7.65	30	Y
2/19	7.74	30	Y
2/20	7.80	26	Y
2/21	7.73	28	Y
2/22	7.74	28	Y
2/23	7.74	24	Y
2/24	7.84	26	Y
2/25	7.52	24	Y
2/26	7.68	24	Y
2/27	7.76	26	Y
2/28	7.70	26	Y
(No = N = Excursion) Total N's:			0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: EP-A Finished Water Pump Stations

Sample Period: February 2025
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)


Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	<i>(alkalinity)</i>
PO4	<input type="text"/>	<i>(Othophosphate)</i>
Other	<input type="text"/>	<i>(_____)</i>

Print Name: Todd Evers

Signature: 

Date: 3/4/2025

Send to DWP within 10 days after end of sampling period.