

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
3/1	7.70	28	Y
3/2	7.72	30	Y
3/3	7.71	30	Y
3/4	7.73	30	Y
3/5	7.77	32	Y
3/6	7.77	28	Y
3/7	7.68	32	Y
3/8	7.65	32	Y
3/9	7.70	32	Y
3/10	7.68	32	Y
3/11	7.67	34	Y
3/12	7.72	30	Y
3/13	7.74	34	Y
3/14	7.68	34	Y
3/15	7.80	32	Y
3/16	7.66	32	Y
3/17	7.65	32	Y
3/18	7.71	32	Y
3/19	7.73	32	Y
3/20	7.84	30	Y
3/21	7.65	28	Y
3/22	7.65	28	Y
3/23	7.75	28	Y
3/24	7.63	28	Y
3/25	7.73	30	Y
3/26	7.72	32	Y
3/27	7.76	30	Y
3/28	7.75	30	Y
3/29	7.73	30	Y
3/30	7.74	32	Y
3/31	7.73	30	Y
(No = N = Excursion) Total N's:			0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission
Entry Point: EP-A Finished Water Pump Stations
Sample Period: March 2025
 Month / Year

Number of excursions this month: 0
 (count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2
 Alk (alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Todd Evers
Signature: 
Date: 4/2/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350. Portland, OR 97293-0350
 Phone (971) 673-0405 website: <http://healthoregon.gov/dwp/>