

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
4/1	7.71	32	Y
4/2	7.67	30	Y
4/3	7.56	32	Y
4/4	7.63	32	Y
4/5	7.64	34	Y
4/6	7.68	36	Y
4/7	7.71	34	Y
4/8	7.65	34	Y
4/9	7.82	30	Y
4/10	7.67	30	Y
4/11	7.69	30	Y
4/12	7.68	32	Y
4/13	7.71	34	Y
4/14	7.71	34	Y
4/15	7.75	34	Y
4/16	7.70	32	Y
4/17	7.64	34	Y
4/18	7.67	34	Y
4/19	7.62	36	Y
4/20	7.62	38	Y
4/21	7.68	36	Y
4/22	7.67	36	Y
4/23	7.58	40	Y
4/24	7.71	37	Y
4/25	7.83	38	Y
4/26	7.65	38	Y
4/27	7.62	40	Y
4/28	7.69	39	Y
4/29	7.69	40	Y
4/30	7.75	38	Y
(No = N = Excursion) Total N's:			0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission
Entry Point: EP-A Finished Water Pump Stations
Sample Period: April 2025
 Month / Year

Number of excursions this month: 0
 (count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2
 Alk (alkalinity)
 PO4 (Orthophosphate)
 Other ()

Print Name: Todd Evers
Signature: 
Date: 5/5/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350. Portland, OR 97293-0350
 Phone (971) 673-0405 website: <http://healthoregon.gov/dwp/>