

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
6/1	7.76	34	Y
6/2	7.74	34	Y
6/3	7.70	34	Y
6/4	7.74	34	Y
6/5	7.78	34	Y
6/6	7.76	34	Y
6/7	7.72	30	Y
6/8	7.76	32	Y
6/9	7.72	32	Y
6/10	7.76	30	Y
6/11	7.77	32	Y
6/12	7.73	30	Y
6/13	7.63	32	Y
6/14	7.61	28	Y
6/15	7.57	28	Y
6/16	7.61	30	Y
6/17	7.53	30	Y
6/18	7.70	30	Y
6/19	7.76	30	Y
6/20	7.76	30	Y
6/21	7.74	30	Y
6/22	7.72	32	Y
6/23	7.68	32	Y
6/24	7.78	32	Y
6/25	7.68	32	Y
6/26	7.79	32	Y
6/27	7.66	32	Y
6/28	7.62	32	Y
6/29	7.65	30	Y
6/30	7.68	32	Y
(No = N = Excursion) Total N's:			0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission
Entry Point: EP-A Finished Water Pump Stations
Sample Period: June 2025
 Month / Year

Number of excursions this month: 0
 (count the number of days when any WQP was less than the minimum.)


Total number of excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2
 Alk (alkalinity)
 PO4 (Othophosphate)
 Other ()

Print Name: Todd Evers

Signature: 

Date: 7/2/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350. Portland, OR 97293-0350
 Phone (971) 673-0405 website: <http://healthoregon.gov/dwp/>