

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average		Minimums met? Y / N
	FW pH	FW Alkalinity	
7/1	7.63	30	Y
7/2	7.70	30	Y
7/3	7.75	30	Y
7/4	7.74	28	Y
7/5	7.74	30	Y
7/6	7.73	30	Y
7/7	7.75	30	Y
7/8	7.78	30	Y
7/9	7.73	30	Y
7/10	7.71	28	Y
7/11	7.70	28	Y
7/12	7.56	28	Y
7/13	7.68	28	Y
7/14	7.60	28	Y
7/15	7.47	28	Y
7/16	7.68	30	Y
7/17	7.70	28	Y
7/18	7.70	30	Y
7/19	7.75	28	Y
7/20	7.72	30	Y
7/21	7.73	28	Y
7/22	7.64	30	Y
7/23	7.75	30	Y
7/24	7.56	28	Y
7/25	7.63	28	Y
7/26	7.63	28	Y
7/27	7.63	28	Y
7/28	7.64	26	Y
7/29	7.64	28	Y
7/30	7.68	24	Y
7/31	7.72	26	Y

(No = N = Excursion) **Total N's:** 0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: EP-A Finished Water Pump Stations

Sample Period: July 2025

Month / Year

Number of excursions this month: 0

(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality

Parameters as set by

pH	7.2	
Alk		(alkalinity)
PO4		(Othophosphate)
Other		()

Print Name: Todd Evers

Signature:

Date: 8/4/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350. Portland, OR 97293-0350
Phone (971) 673-0405 website: <http://healthoregon.gov/dwp/>