

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average		Minimums met? Y / N
	FW pH	FW Alkalinity	
8/1	7.73	28	Y
8/2	7.75	28	Y
8/3	7.72	30	Y
8/4	7.71	28	Y
8/5	7.71	28	Y
8/6	7.62	28	Y
8/7	7.61	28	Y
8/8	7.56	30	Y
8/9	7.66	28	Y
8/10	7.69	28	Y
8/11	7.65	28	Y
8/12	7.53	28	Y
8/13	7.70	28	Y
8/14	7.75	28	Y
8/15	7.70	28	Y
8/16	7.69	30	Y
8/17	7.67	28	Y
8/18	7.70	30	Y
8/19	7.65	28	Y
8/20	7.74	32	Y
8/21	7.75	30	Y
8/22	7.62	28	Y
8/23	7.69	28	Y
8/24	7.59	30	Y
8/25	7.71	30	Y
8/26	7.68	30	Y
8/27	7.70	30	Y
8/28	7.71	30	Y
8/29	7.72	30	Y
8/30	7.69	30	Y
8/31	7.64	30	Y

(No = N = Excursion)

Total N's:

0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: EP-A Finished Water Pump Stations

Sample Period: August 2025

Month / Year

Number of excursions this month:

0

(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality

Parameters as set by

pH	7.2	
Alk		(alkalinity)
PO4		(Othophosphate)
Other		()

Print Name:

Todd Evers

Signature:

Todd Evers

Date:

9/3/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350. Portland, OR 97293-0350

Phone (971) 673-0405 website: <http://healthoregon.gov/dwp/>