

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
9/1	7.70	30	Y
9/2	7.69	30	Y
9/3	7.65	30	Y
9/4	7.59	32	Y
9/5	7.65	32	Y
9/6	7.69	30	Y
9/7	7.65	32	Y
9/8	7.65	32	Y
9/9	7.67	30	Y
9/10	7.75	30	Y
9/11	7.70	30	Y
9/12	7.68	30	Y
9/13	7.68	30	Y
9/14	7.70	30	Y
9/15	7.65	30	Y
9/16	7.72	30	Y
9/17	7.72	30	Y
9/18	7.40	30	Y
9/19	7.60	32	Y
9/20	7.68	32	Y
9/21	7.69	32	Y
9/22	7.67	30	Y
9/23	7.65	30	Y
9/24	7.70	32	Y
9/25	7.73	32	Y
9/26	7.70	32	Y
9/27	7.68	32	Y
9/28	7.67	32	Y
9/29	7.72	32	Y
9/30	7.71	32	Y

(No = N = Excursion) **Total N's:** 0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission
Entry Point: EP-A Finished Water Pump Stations
Sample Period: September 2025
 Month / Year

Number of excursions this month: 0
 (count the number of days when any WQP was less than the minimum.)


Total number of excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2
 Alk (alkalinity)
 PO4 (Othophosphate)
 Other ()

Print Name: Todd Evers

Signature: 

Date: 10/1/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350. Portland, OR 97293-0350
 Phone (971) 673-0405 website: <http://healthoregon.gov/dwp/>