

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
10/1	7.68	30	Y
10/2	7.69	34	Y
10/3	7.78	34	Y
10/4	7.75	34	Y
10/5	7.68	32	Y
10/6	7.64	32	Y
10/7	7.56	32	Y
10/8	7.66	32	Y
10/9	7.71	32	Y
10/10	7.73	32	Y
10/11	7.73	34	Y
10/12	7.77	34	Y
10/13	7.71	34	Y
10/14	7.71	32	Y
10/15	7.66	34	Y
10/16	7.78	34	Y
10/17	7.69	36	Y
10/18	7.80	34	Y
10/19	7.61	34	Y
10/20	7.68	32	Y
10/21	7.75	34	Y
10/22	7.74	34	Y
10/23	7.78	34	Y
10/24	7.74	32	Y
10/25	7.64	34	Y
10/26	7.61	32	Y
10/27	7.66	30	Y
10/28	7.75	34	Y
10/29	7.74	32	Y
10/30	7.61	36	Y
10/31	7.68	38	Y

(No = N = Excursion)

Total N's:

0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: EP-A Finished Water Pump Stations

Sample Period: October 2025

Month / Year

Number of excursions this month:

0

(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months:

0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

Minimum Water Quality

Parameters as set by

pH	7.2	
Alk		(alkalinity)
PO4		(Othophosphate)
Other		()

Print Name:

Todd Evers

Signature:

Todd Evers

Date:

11/5/2025

Send to DWP within 10 days after end of sampling period.

OHA Drinking Water Program, PO Box 14350. Portland, OR 97293-0350

Phone (971) 673-0405 website: <http://healthoregon.gov/dwp/>