

Oregon
Health
Authority

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

DATE	Average FW pH	FW Alkalinity	Minimums met? Y / N
11/1	7.79	36	Y
11/2	7.78	30	Y
11/3	7.89	32	Y
11/4	7.89	34	Y
11/5	7.80	32	Y
11/6	7.82	32	Y
11/7	7.75	30	Y
11/8	7.79	30	Y
11/9	7.81	32	Y
11/10	7.71	34	Y
11/11	7.72	34	Y
11/12	7.69	36	Y
11/13	7.72	38	Y
11/14	7.82	38	Y
11/15	7.86	38	Y
11/16	7.65	36	Y
11/17	7.77	38	Y
11/18	7.86	36	Y
11/19	7.79	38	Y
11/20	7.80	38	Y
11/21	7.84	40	Y
11/22	7.84	40	Y
11/23	7.78	40	Y
11/24	7.78	40	Y
11/25	7.79	40	Y
11/26	7.73	38	Y
11/27	7.72	32	Y
11/28	7.77	32	Y
11/29	7.71	32	Y
11/30	7.75	32	Y

(No = N = Excursion) **Total N's:** 0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: EP-A Finished Water Pump Stations

Sample Period: November 2025
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH	7.2	
Alk		<i>(alkalinity)</i>
PO4		<i>(Othophosphate)</i>
Other		<i>(_____)</i>

Print Name: Todd Evers

Signature:

Date: 12/2/2025

Send to DWP within 10 days after end of sampling period.