

Oregon
Health
Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DATE	Average		Minimums met? Y/N
	FW pH	FW Alkalinity	
1/1	7.78	32	Y
1/2	7.77	34	Y
1/3	7.79	30	Y
1/4	7.85	30	Y
1/5	7.90	30	Y
1/6	7.88	30	Y
1/7	7.69	28	Y
1/8	7.72	26	Y
1/9	7.73	26	Y
1/10	7.80	28	Y
1/11	7.88	30	Y
1/12	7.79	28	Y
1/13	7.87	28	Y
1/14	7.70	34	Y
1/15	7.53	32	Y
1/16	7.66	32	Y
1/17	7.70	32	Y
1/18	7.73	32	Y
1/19	7.74	32	Y
1/20	7.76	34	Y
1/21	7.72	34	Y
1/22	7.80	32	Y
1/23	7.83	32	Y
1/24	7.88	34	Y
1/25	7.90	36	Y
1/26	7.90	36	Y
1/27	7.93	36	Y
1/28	7.88	28	Y
1/29	7.81	36	Y
1/30	7.79	38	Y
1/31	7.77	36	Y
(No = N = Excursion) Total N's:			0

ENTRY POINT

PWS: 41 00379

System Name: Joint Water Commission

Entry Point: EP-A Finished Water Pump Stations

Sample Period: January 2026
Month / Year

Number of excursions this month: 0
(count the number of days when any WQP was less than the minimum.)

Total number of excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)

for OHA use only

**Minimum Water Quality
Parameters as set by**

pH	<input style="width: 90%;" type="text" value="7.2"/>	
Alk	<input style="width: 90%;" type="text"/>	<i>(alkalinity)</i>
PO4	<input style="width: 90%;" type="text"/>	<i>(Othophosphate)</i>
Other	<input style="width: 90%;" type="text"/>	<i>(_____)</i>

Print Name: Todd Evers

Signature: 

Date: 2/4/2026

Send to DWP within 10 days after end of sampling period.