

Oregon  
Health  
Authority

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

DATE	Average FW pH	FW Alkalinity	Minimums met? Y/N
3/1	7.78	30	Y
3/2	7.78	34	Y
3/3	7.78	36	Y
3/4	7.63	34	Y
3/5	7.64	32	Y
3/6	7.82	34	Y
3/7	7.77	34	Y
3/8	7.75	34	Y
3/9	7.80	32	Y
3/10	7.83	34	Y
3/11	7.81	30	Y
3/12	7.87	22	Y
3/13	7.79	24	Y
3/14	7.77	24	Y
3/15	7.77	26	Y
3/16	7.68	26	Y
3/17	7.69	26	Y
3/18	7.79	30	Y
3/19	7.80	30	Y
3/20	7.79	32	Y
3/21	7.70	32	Y
3/22	7.72	32	Y
3/23	7.85	30	Y
3/24	7.62	34	Y
3/25	7.72	36	Y
3/26	7.73	34	Y
3/27	7.97	34	Y
3/28	7.71	38	Y
3/29	7.86	38	Y
3/30	7.85	38	Y
3/31	7.66	38	Y
(No = N = Excursion)	<b>Total N's:</b>	<b>0</b>	

**ENTRY POINT**

**PWS:      41 00379**

**System Name:** Joint Water Commission

**Entry Point:** EP-A Finished Water Pump Stations

**Sample Period:** March 2026  
*Month / Year*

**Number of excursions this month:** 0  
*(count the number of days when any WQP was less than the minimum.)*

**Total number of excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative.)*

*for OHA use only*

**Minimum Water Quality  
Parameters as set by**

pH	<input style="width: 90%;" type="text" value="7.2"/>	
Alk	<input style="width: 90%;" type="text"/>	<i>(alkalinity)</i>
PO4	<input style="width: 90%;" type="text"/>	<i>(Othophosphate)</i>
Other	<input style="width: 90%;" type="text"/>	<i>(_____)</i>

**Print Name:** Todd Evers

**Signature:** 

**Date:** 4/2/2026

Send to DWP within 10 days after end of sampling period.